



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041
N-14

Lab# 2666

Customer		Sample Collection			
Facility Name:	Danbury Farms	Date:	7/14/25		
Address:	100 Carriage Dr Freedom, PA 15042	Time:	12:00 PM		
Matrix:	Recreational Water	Method:	Grab		
Source Type:	Pool				
Accredited Analysis		Results	Reporting limit	Incubation Date/Time	Analyst
Escherichia Coli:	Absent	Absent	7/15/25	9:30 AM	EB
Total coliforms:	0/100mls	2/100mls	7/15/25	9:30 AM	EB
Standard plate count:	0/ml	200/ml	7/14/25	3:53 PM	EB

Field Analysis	Results	Reporting limit	Date/Time	Analyst	Method
pH:	7.6 SU	7.2 - 7.8 SU	7/14/25	12:00 PM	ZR
Chlorine:	1.5 mg/l	1.0 - 5.0 mg/l	7/14/25	12:00 PM	ZR
Turbidity:	1 NTU	1 - 2 NTU	7/14/25	12:00 PM	ZR

Sample comments

Andre Smith, Lead Supervisor

(When exceeding reporting limit pool or spa is unfit)

Andre Smith



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041
N-14

Lab# 2666

Customer		Sample Collection			
Facility Name:	Danbury Farms	Date:	7/14/25		
Address:	100 Carriage Dr Freedom, PA 15042	Time:	12:00 PM		
Matrix:	Recreational Water	Method:	Grab		
Source Type:	Pool				
Accredited Analysis		Results	Reporting limit	Incubation Date/Time	Analyst
Escherichia Coli:	Absent	Absent	7/15/25	9:30 AM	EB
Total coliforms:	0/100mls	2/100mls	7/15/25	9:30 AM	EB
Standard plate count:	0/ml	200/ml	7/14/25	3:53 PM	EB

Field Analysis	Results	Reporting limit	Date/Time	Analyst	Method
pH:	7.6 SU	7.2 - 7.8 SU	7/14/25	12:00 PM	ZR
Chlorine:	1.5 mg/l	1.0 - 5.0 mg/l	7/14/25	12:00 PM	ZR
Turbidity:	1 NTU	1 - 2 NTU	7/14/25	12:00 PM	ZR

Sample comments

Andre Smith, Lead Supervisor

(When exceeding reporting limit pool or spa is unfit)

Andre Smith