



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

N-2

Lab# 237

Customer

Facility Name: North Hills High School

Address: 53 Rochester Rd.
Pittsburgh, PA 15229

Sample Collection

Date: 10/29/25
Time: 8:00 AM
Method: Grab

Matrix: Recreational Water

Source Type: Pool Shallow

Sample Final Analysis

Date: 10/31/25
Time: 5:00 PM
Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	10/29/25	4:25 PM	SL	SM 9222G
Total coliforms:	0/100mls	2/100mls	10/29/25	4:25 PM	SL	SM 9222B
Standard plate count:	0/ml	200/ml	10/29/25	4:10 PM	SL	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.4 SU	7.2 - 7.8 SU	10/29/25	8:00 AM	VH	DPD
Chlorine:	3.0 mg/l	1.0 - 5.0 mg/l	10/29/25	8:00 AM	VH	DPD
Turbidity:	1 NTU	1 - 2 NTU	10/29/25	8:00 AM	VH	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor