



**Dream Pools And Spas**  
**1105 Washington Blvd**  
**Pittsburgh, Pennsylvania 15206**  
**(412) 661- 7665**  
**Laboratory Analysis Report**

Lab ID No. 02-04041  
**APM 1**

**Lab# 2001**

**Customer**                      *American Pools Management*  
3261 Babcock Blvd.  
Pittsburgh, PA 15237

*Facility Name:*                      1400 Main @ Southpointe  
  
*Address:*                              1400 Main St.  
Canonsburg, PA 15317

*Matrix:*                                Recreational Water  
  
*Source Type:*                        Spa

**Sample Collection**

*Date:*                                      7/22/25  
*Time:*                                    12:15 PM  
*Method:*                                Grab

**Sample Final Analysis**

*Date:*                                      7/25/25  
*Time:*                                    10:00 AM  
*Analyst:*                                AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	7/23/25	12:00 PM	AH	SM 9222G
Total coliforms:	0/100mls	2/100mls	7/23/25	12:00 PM	AH	SM 9222B
Standard plate count:	0/ml	200/ml	7/22/25	6:00 PM	SL	SM 9215B
Additional Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Fecal Streptococcus	0/100mls	2/100mls	7/23/25	12:20 PM	SL	SM 9230C

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.8 SU	7.2 - 7.8 SU	7/22/25	12:15 PM	AF	DPD
Chlorine:	7.5 mg/l	1.0 - 5.0 mg/l	7/22/25	12:15 PM	AF	DPD
Turbidity:	1 NTU	1 - 2 NTU	7/22/25	12:15 PM	AF	Visual

**Sample comments**

*Andre Smith*

( When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor



**Dream Pools And Spas**  
**1105 Washington Blvd**  
**Pittsburgh, Pennsylvania 15206**  
**(412) 661- 7665**  
**Laboratory Analysis Report**

Lab ID No. 02-04041  
**APM 1**

**Lab# 2001**

**Customer**                      *American Pools Management*  
3261 Babcock Blvd.  
Pittsburgh, PA 15237

*Facility Name:*                      1400 Main @ Southpointe  
  
*Address:*                              1400 Main St.  
Canonsburg, PA 15317

**Sample Collection**

*Date:*                                      7/22/25  
*Time:*                                      12:15 PM  
*Method:*                                  Grab

**Sample Final Analysis**

*Date:*                                      7/25/25  
*Time:*                                      10:00 AM  
*Analyst:*                                  AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time	Analyst	Method
---------------------	---------	-----------------	----------------------	---------	--------

Escherichia Coli:	Absent	Absent	7/23/25	12:00 PM	AH	SM 9222G
Total coliforms:	0/100mls	2/100mls	7/23/25	12:00 PM	AH	SM 9222B
Standard plate count:	0/ml	200/ml	7/22/25	6:00 PM	SL	SM 9215B

Additional Analysis	Results	Reporting limit	Incubation Date/Time	Analyst	Method
---------------------	---------	-----------------	----------------------	---------	--------

Fecal Streptococcus	0/100mls	2/100mls	7/23/25	12:20 PM	SL	SM 9230C
---------------------	----------	----------	---------	----------	----	----------

Field Analysis	Results	Reporting limit	Date/Time	Analyst	Method
----------------	---------	-----------------	-----------	---------	--------

pH:	7.8 SU	7.2 - 7.8 SU	7/22/25	12:15 PM	AF	DPD
Chlorine:	7.5 mg/l	1.0 - 5.0 mg/l	7/22/25	12:15 PM	AF	DPD
Turbidity:	1 NTU	1 - 2 NTU	7/22/25	12:15 PM	AF	Visual

**Sample comments**

*Andre Smith*

( When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor