



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

S-3

Lab# 290

Customer

Facility Name: Springhill Suites
Address: 16 Trinity Point Dr.
Washington, PA 15301

Sample Collection

Date: 9/15/25
Time: 9:30 AM
Method: Grab

Matrix: Recreational Water

Sample Final Analysis

Date: 9/18/25
Time: 9:00 AM
Analyst: AS

Source Type: Pool

Accredited Analysis	Results	Reporting limit	Incubation	Date/Time	Analyst	Method
Escherichia Coli:	Absent	Absent	9/16/25	9:00 AM	JC	SM 9222G
Total coliforms:	0/100mls	2/100mls	9/16/25	9:00 AM	JC	SM 9222B
Standard plate count:	0/ml	200/ml	9/15/25	3:30 PM	AS	SM 9215B

Field Analysis	Results	Reporting limit		Date/Time	Analyst	Method
pH:	7.2 SU	7.2 - 7.8 SU	9/15/25	9:30 AM	GR	DPD
Chlorine:	5.0 mg/l	1.0 - 5.0 mg/l	9/15/25	9:30 AM	GR	DPD
Turbidity:	1 NTU	1 - 2 NTU	9/15/25	9:30 AM	GR	Visual

Sample comments

Andre Smith

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor