



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

E-1

Lab# 109

Customer

Facility Name: Gateway High School
Address: 3000 Gateway Blvd.
Monroeville, PA 15146

Matrix: Recreational Water
Source Type: Shallow End

Sample Collection

Date: 11/11/25
Time: 11:45 AM
Method: Grab

Sample Final Analysis

Date: 11/14/25
Time: 10:30 AM
Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation	Date/Time	Analyst	Method
Escherichia Coli:	Absent	Absent	11/12/25	10:00 AM	SL	SM 9222G
Total coliforms:	0/100mls	2/100mls	11/12/25	10:00 AM	SL	SM 9222B
Standard plate count:	0/ml	200/ml	11/11/25	2:30 PM	SL	SM 9215B

Field Analysis	Results	Reporting limit		Date/Time	Analyst	Method
pH:	7.6 SU	7.2 - 7.8 SU	11/11/25	11:45 AM	SH	DPD
Chlorine:	2.0 mg/l	1.0 - 5.0 mg/l	11/11/25	11:45 AM	SH	DPD
Turbidity:	1 NTU	1 - 2 NTU	11/11/25	11:45 AM	SH	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor