



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

C-10

Lab# 500

Customer

Facility Name: Ditheridge House
Address: 220 N. Ditheridge St
Pittsburgh, PA 15213
Matrix: Recreational Water
Source Type: Pool

Sample Collection

Date: 7/14/25
Time: 11:10 AM
Method: Grab

Sample Final Analysis

Date: 7/17/25
Time: 8:30 AM
Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	7/15/25	9:00 AM	EB	SM 9222G
Total coliforms:	0/100mls	2/100mls	7/15/25	9:00 AM	EB	SM 9222B
Standard plate count:	0/ml	200/ml	7/14/25	3:04 PM	EB	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.4 SU	7.2 - 7.8 SU	7/14/25	11:10 AM	LM	DPD
Chlorine:	2.0 mg/l	1.0 - 5.0 mg/l	7/14/25	11:10 AM	LM	DPD
Turbidity:	1 NTU	1 - 2 NTU	7/14/25	11:10 AM	LM	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Anaë Smith



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

C-10

Lab# 500

Customer

Facility Name: Ditheridge House
Address: 220 N. Ditheridge St
Pittsburgh, PA 15213
Matrix: Recreational Water
Source Type: Pool

Sample Collection

Date: 7/14/25
Time: 11:10 AM
Method: Grab

Sample Final Analysis

Date: 7/17/25
Time: 8:30 AM
Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	7/15/25	9:00 AM	EB	SM 9222G
Total coliforms:	0/100mls	2/100mls	7/15/25	9:00 AM	EB	SM 9222B
Standard plate count:	0/ml	200/ml	7/14/25	3:04 PM	EB	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.4 SU	7.2 - 7.8 SU	7/14/25	11:10 AM	LM	DPD
Chlorine:	2.0 mg/l	1.0 - 5.0 mg/l	7/14/25	11:10 AM	LM	DPD
Turbidity:	1 NTU	1 - 2 NTU	7/14/25	11:10 AM	LM	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Anaë Smith