



**Dream Pools and Spas**  
**1105 Washington Blvd**  
**Pittsburgh, Pennsylvania 15206**  
**(412) 661- 7665**  
**Laboratory Analysis Report**

Lab ID No. 02-04041

**E - 10**

**Lab# 469**

**Customer**

**Facility Name:** *Holiday Inn Express*  
**Address:** *137 Blair St.*  
*Greensburg, PA 15601*

**Sample Collection**

**Date:** *5/29/25*  
**Time:** *4:00 PM*  
**Method:** *Grab*

**Matrix:** *Recreational Water*  
**Source Type:** *Pool*

**Sample Final Analysis**

**Date:** *5/31/25*  
**Time:** *3:30 PM*  
**Analyst:** *AS*

<b>Accredited Analysis</b>	<b>Results</b>	<b>Reporting limit</b>	<b>Incubation Date/Time</b>		<b>Analyst</b>	<b>Method</b>
Escherichia Coli:	Absent	Absent	5/29/25	6:05 PM	SL	SM 9222G
Total coliforms:	0/100mls	2/100mls	5/29/25	6:05 PM	SL	SM 9222B
Standard plate count:	0/ml	200/ml	5/29/25	6:05 PM	SL	SM 9215B

<b>Field Analysis</b>	<b>Results</b>	<b>Reporting limit</b>	<b>Date/Time</b>		<b>Analyst</b>	<b>Method</b>
pH:	8.0 SU	7.2 - 7.8 SU	5/29/25	4:00 PM	BH	DPD
Chlorine:	10.0 mg/l	1.0 - 5.0 mg/l	5/29/25	4:00 PM	BH	DPD
Turbidity:	1 NTU	1 - 2 NTU	5/29/25	4:00 PM	BH	Visual

**Sample comments**

( When exceeding reporting limit pool or spa is unfit)

*Andre Smith*

Andre Smith, Lead Supervisor



**Dream Pools and Spas**  
**1105 Washington Blvd**  
**Pittsburgh, Pennsylvania 15206**  
**(412) 661- 7665**  
**Laboratory Analysis Report**

Lab ID No. 02-04041

**E - 10**

**Lab# 469**

**Customer**

Facility Name: *Holiday Inn Express*  
Address: *137 Blair St.*  
*Greensburg, PA 15601*

**Sample Collection**

Date: *5/29/25*  
Time: *4:00 PM*  
Method: *Grab*

Matrix: *Recreational Water*  
Source Type: *Pool*

**Sample Final Analysis**

Date: *5/31/25*  
Time: *3:30 PM*  
Analyst: *AS*

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	5/29/25	6:05 PM	SL	SM 9222G
Total coliforms:	0/100mls	2/100mls	5/29/25	6:05 PM	SL	SM 9222B
Standard plate count:	0/ml	200/ml	5/29/25	6:05 PM	SL	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	8.0 SU	7.2 - 7.8 SU	5/29/25	4:00 PM	BH	DPD
Chlorine:	10.0 mg/l	1.0 - 5.0 mg/l	5/29/25	4:00 PM	BH	DPD
Turbidity:	1 NTU	1 - 2 NTU	5/29/25	4:00 PM	BH	Visual

**Sample comments**

( When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor