



**Dream Pools and Spas**  
**1105 Washington Blvd**  
**Pittsburgh, Pennsylvania 15206**  
**(412) 661- 7665**  
**Laboratory Analysis Report**

Lab ID No. 02-04041

**E-1**

**Lab# 356**

**Customer**

Facility Name: YMCA - East Suburban

Address: 2200 Golden Mile Hwy.  
Plum, PA 15239

Matrix: Recreational Water

Source Type: Deep End

**Sample Collection**

Date: 10/21/25

Time: 12:15 PM

Method: Grab

**Sample Final Analysis**

Date: 10/24/25

Time: 10:00 AM

Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	10/22/25	9:30 AM	JC	SM 9222G
Total coliforms:	0/100mls	2/100mls	10/22/25	9:30 AM	JC	SM 9222B
Standard plate count:	0/ml	200/ml	10/21/25	3:00 PM	SL	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.6 SU	7.2 - 7.8 SU	10/21/25	12:15 PM	SH	DPD
Chlorine:	2.0 mg/l	1.0 - 5.0 mg/l	10/21/25	12:15 PM	SH	DPD
Turbidity:	1 NTU	1 - 2 NTU	10/21/25	12:15 PM	SH	Visual

**Sample comments**

( When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor