



**Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661-7665
Laboratory Analysis Report**

Lab ID No. 02-04041
C-2

Lab# 446

<u>Customer</u>		<u>Sample Collection</u>	
Facility Name:	Comfort Inn	Date:	11/18/25
Address:	830 East Ohio St. Pittsburgh, PA 15222	Time:	12:00 AM
Matrix:	Recreational Water	Method:	Grab
Source Type:	Pool		
<u>Accredited Analysis</u>		<u>Results</u>	<u>Reporting limit</u>
Escherichia Coli:	Absent	Absent	11/19/25
Total coliforms:	0/100mls	2/100mls	11/19/25
Standard plate count:	0/ml	200/ml	11/18/25
			10:30 AM
			AS
			SM 9222G

<u>Field Analysis</u>	<u>Results</u>	<u>Reporting limit</u>	<u>Date/Time</u>	<u>Analyst</u>	<u>Method</u>
pH:	8.0 SU	7.2 - 7.8 SU	11/18/25	1:20 PM	BH
Chlorine:	5.0 mg/l	1.0 - 5.0 mg/l	11/18/25	1:20 PM	BH
Turbidity:	1 NTU	1 - 2 NTU	11/18/25	1:20 PM	BH
					Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor