



**Dream Pools And Spas**  
**1105 Washington Blvd**  
**Pittsburgh, Pennsylvania 15206**  
**(412) 661- 7665**  
**Laboratory Analysis Report**

Lab ID No. 02-04041  
**APM 1**

**Lab# 2059**

**Customer**

*American Pools Management*  
*3261 Babcock Blvd.*  
*Pittsburgh, PA 15237*

**Sample Collection**

*Facility Name: Bright Oaks*  
*Address: 600 N. Branch Road*  
*Oakdale, PA 15071*

*Date: 7/15/25*  
*Time: 9:00 AM*  
*Method: Grab*

**Sample Final Analysis**

*Matrix: Recreational Water*  
*Source Type: Pool*

*Date: 7/18/25*  
*Time: 9:30 AM*  
*Analyst: AS*

Accredited Analysis	Results	Reporting limit	Incubation Date/Time	Analyst	Method
Escherichia Coli:	Absent	Absent	7/16/25 10:50 AM	EB	SM 9222G
Total coliforms:	0/100mls	2/100mls	7/16/25 10:50 AM	EB	SM 9222B
Standard plate count:	0/ml	200/ml	7/15/25 4:20 PM	AH	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time	Analyst	Method
pH:	7.6 SU	7.2 - 7.8 SU	7/15/25 9:00 AM	AH	DPD
Chlorine:	5.0 mg/l	1.0 - 5.0 mg/l	7/15/25 9:00 AM	AH	DPD
Turbidity:	1 NTU	1 - 2 NTU	7/15/25 9:00 AM	AH	Visual

**Sample comments**

( When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor



**Dream Pools And Spas**  
**1105 Washington Blvd**  
**Pittsburgh, Pennsylvania 15206**  
**(412) 661- 7665**  
**Laboratory Analysis Report**

Lab ID No. 02-04041  
**APM 1**

**Lab# 2059**

**Customer**      *American Pools Management*  
*3261 Babcock Blvd.*  
*Pittsburgh, PA 15237*

**Facility Name:**      *Bright Oaks*  
**Address:**      *600 N. Branch Road*  
*Oakdale, PA 15071*

**Sample Collection**

**Date:**      *7/15/25*  
**Time:**      *9:00 AM*  
**Method:**      *Grab*

**Matrix:**      *Recreational Water*  
**Source Type:**      *Pool*

**Sample Final Analysis**

**Date:**      *7/18/25*  
**Time:**      *9:30 AM*  
**Analyst:**      *AS*

<b>Accredited Analysis</b>	<b>Results</b>	<b>Reporting limit</b>	<b>Incubation Date/Time</b>	<b>Analyst</b>	<b>Method</b>
Escherichia Coli:	Absent	Absent	7/16/25      10:50 AM	EB	SM 9222G
Total coliforms:	0/100mls	2/100mls	7/16/25      10:50 AM	EB	SM 9222B
Standard plate count:	0/ml	200/ml	7/15/25      4:20 PM	AH	SM 9215B

<b>Field Analysis</b>	<b>Results</b>	<b>Reporting limit</b>	<b>Date/Time</b>	<b>Analyst</b>	<b>Method</b>
pH:	7.6 SU	7.2 - 7.8 SU	7/15/25      9:00 AM	AH	DPD
Chlorine:	5.0 mg/l	1.0 - 5.0 mg/l	7/15/25      9:00 AM	AH	DPD
Turbidity:	1 NTU	1 - 2 NTU	7/15/25      9:00 AM	AH	Visual

**Sample comments**

( When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor