



**Dream Pools and Spas**  
**1105 Washington Blvd**  
**Pittsburgh, Pennsylvania 15206**  
**(412) 661- 7665**  
**Laboratory Analysis Report**

Lab ID No. 02-04041  
**APM**  
**Lab# 2608**

C2

**Customer**      *American Pools Management*  
3261 Babcock Blvd.  
Pittsburgh, PA 15237

*Facility Name:*      Yards @ 3 Crossings

*Address:*            2645 Railroad St.  
Pittsburgh, PA 15222

*Matrix:*              Recreational Water

*Source Type:*       Spa

**Sample Collection**

*Date:*                  2/3/26  
*Time:*                10:10 AM  
*Method:*             Grab

**Sample Final Analysis**

*Date:*                  2/6/26  
*Time:*                10:30 AM  
*Analyst:*             AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time	Analyst	Method
Escherichia Coli:	Absent	Absent	1/0/00      10:00 AM	SL	SM 9222G

Total coliforms:	0/100mls	2/100mls	1/0/00      10:00 AM	SL	SM 9222B
------------------	----------	----------	----------------------	----	----------

Standard plate count:	0/ml	200/ml	1/0/00      3:40 PM	SL	SM 9215B
-----------------------	------	--------	---------------------	----	----------

Additional Analysis	Results	Reporting limit	Incubation Date/Time	Analyst	Method
Fecal Streptococcus	0/100mls	2/100mls	2/4/26      11:00 AM	SL	SM 9230C

Field Analysis	Results	Reporting limit	Date/Time	Analyst	Method
pH:	7.4 SU	7.2 - 7.8 SU	2/3/26      10:10 AM	BH	DPD
Chlorine:	10.0 mg/l	1.0 - 5.0 mg/l	2/3/26      10:10 AM	BH	DPD
Turbidity:	1 NTU	1 - 2 NTU	2/3/26      10:10 AM	BH	Visual

**Sample comments**

Andre Smith, Lead Supervisor

( When exceeding reporting limit pool or spa is unfit)