



**Dream Pools and Spas**  
**1105 Washington Blvd**  
**Pittsburgh, Pennsylvania 15206**  
**(412) 661-7665**  
**Laboratory Analysis Report**

Lab ID No. 02-04041

**SERVICE**

Lab# 313

**Customer**

Facility Name: UPMC Sports Rehab - Cranberry

Address: 8000 Cranberry Springs Drive  
Cranberry Township, PA 16066

Matrix: Recreational Water

Source Type: Spa

**Sample Collection**

Date: 9/16/25

Time: 11:05 AM

Method: Grab

**Sample Final Analysis**

Date: 9/19/25

Time: 9:00 AM

Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time	Analyst	Method	
Escherichia Coli:	Absent	Absent	9/17/25	10:30 AM	JC	SM 9222G
Total coliforms:	0/100mls	2/100mls	9/17/25	10:30 AM	JC	SM 9222B
Standard plate count:	0/ml	200/ml	9/16/25	5:45 PM	AS	SM 9215B
Additional Analysis	Results	Reporting limit	Incubation Date/Time	Analyst	Method	
Fecal Streptococcus	0/100mls	2/100mls	9/17/25	10:00 AM	SL	SM 9230C

Field Analysis	Results	Reporting limit	Date/Time	Analyst	Method	
pH:	7.4 SU	7.2 - 7.8 SU	9/16/25	11:05 AM	JR	DPD
Chlorine:	1.5 mg/l	1.0 - 5.0 mg/l	9/16/25	11:05 AM	JR	DPD
Turbidity:	1 NTU	1 - 2 NTU	9/16/25	11:05 AM	JR	Visual

**Sample comments**

A handwritten signature in black ink that reads "Andre Smith". The signature is fluid and cursive, with "Andre" on the first line and "Smith" on the second line.

( When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor