



**Dream Pools And Spas**  
**1105 Washington Blvd**  
**Pittsburgh, Pennsylvania 15206**  
**(412) 661- 7665**  
**Laboratory Analysis Report**

Lab ID No. 02-04041

APM 1

Lab# 2082

**Customer** American Pools Management  
3261 Babcock Blvd.  
Pittsburgh, PA 15237

Facility Name:	Address:	<b>Sample Collection</b>				
		Date:	8/11/25	Time:	1:30 PM	
Matrix:	Source Type:	<b>Sample Final Analysis</b>				
Escherichia Coli:	Absent	Analyst:	8/14/25	Date:	9:00 AM	
Total coliforms:	0/100mls	Method:	1/0/00	Time:		
Standard plate count:	100/ml					
Accredited Analysis	Results	Reporting limit	Incubation Date/Time	Analyst	Method	
Escherichia Coli:	Absent	Absent	8/12/25	11:00 AM	AH	SM 9222G
Total coliforms:	0/100mls	2/100mls	8/12/25	11:00 AM	AH	SM 9222B
Standard plate count:	100/ml	200/ml	8/11/25	6:00 PM	EB	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time	Analyst	Method	
pH:	7.2 SU	7.2 - 7.8 SU	8/11/25	1:30 PM	CW	DPD
Chlorine:	3.0 mg/l	1.0 - 5.0 mg/l	8/11/25	1:30 PM	CW	DPD
Turbidity:	1 NTU	1 - 2 NTU	8/11/25	1:30 PM	CW	Visual

**Sample comments**

*Andre Smith*

(When exceeding reporting limit pool or spa is unfit)

---

Andre Smith, Lead Supervisor



**Dream Pools And Spas**  
**1105 Washington Blvd**  
**Pittsburgh, Pennsylvania 15206**  
**(412) 661- 7665**  
**Laboratory Analysis Report**

Lab ID No. 02-04041

APM 1

Lab# 2082

**Customer** American Pools Management  
3261 Babcock Blvd.  
Pittsburgh, PA 15237

Facility Name:	Address:	<b>Sample Collection</b>			
		Date:	8/11/25	Time:	1:30 PM
Carriage Park Apt.	300 Chatham Park Dr. Pittsburgh, PA 15220	Method:	Grab		
Recreational Water					
Shallow End					

<b>Accredited Analysis</b>	<b>Results</b>	<b>Reporting limit</b>	<b>Incubation Date/Time</b>	<b>Analyst</b>	<b>Method</b>	
Escherichia Coli:	Absent	Absent	8/12/25	11:00 AM	AH	SM 9222G
Total coliforms:	0/100mls	2/100mls	8/12/25	11:00 AM	AH	SM 9222B
Standard plate count:	100/ml	200/ml	8/11/25	6:00 PM	EB	SM 9215B

<b>Field Analysis</b>	<b>Results</b>	<b>Reporting limit</b>	<b>Date/Time</b>	<b>Analyst</b>	<b>Method</b>	
pH:	7.2 SU	7.2 - 7.8 SU	8/11/25	1:30 PM	CW	DPD
Chlorine:	3.0 mg/l	1.0 - 5.0 mg/l	8/11/25	1:30 PM	CW	DPD
Turbidity:	1 NTU	1 - 2 NTU	8/11/25	1:30 PM	CW	Visual

**Sample comments**

*Andre Smith*

(When exceeding reporting limit pool or spa is unfit)

---

Andre Smith, Lead Supervisor