



**Dream Pools and Spas**  
**1105 Washington Blvd**  
**Pittsburgh, Pennsylvania 15206**  
**(412) 661-7665**  
**Laboratory Analysis Report**

Lab ID No. 02-04041

C-2

Lab# 141

<u>Customer</u>		<u>Sample Collection</u>				
Facility Name:	Heinz House	Date:	1/27/26			
Address:	1 Heinz St. Pittsburgh, PA 15212	Time:	1:50 PM			
Matrix:		<u>Sample Final Analysis</u>				
Source Type:	Recreational Water	Date:	1/30/26			
		Time:	11:00 AM			
		Analyst:	AS			
Accredited Analysis	Results	Reporting limit	Incubation Date/Time	Analyst	Method	
Escherichia Coli:	Absent	Absent	1/28/26	10:30 AM	JC	SM 9222G
Total coliforms:	0/100mls	2/100mls	1/28/26	10:30 AM	JC	SM 9222B
Standard plate count:	0/ml	200/ml	1/27/26	5:16 PM	AS	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time	Analyst	Method	
pH:	7.6 SU	7.2 - 7.8 SU	1/27/26	1:50 PM	BH	DPD
Chlorine:	2.0 mg/l	1.0 - 5.0 mg/l	1/27/26	1:50 PM	BH	DPD
Turbidity:	1 NTU	1 - 2 NTU	1/27/26	1:50 PM	BH	Visual

**Sample comments**

( When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor