Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

C-11

Lab# **155**

Customer

Facility Name:	*Holiday Inn*
Address:	*20 S 10th St.*
	Pittsburgh, PA 15203
Matrix:	*Recreational Water*
Source Type:	*Pool*

Sample Collection

Date:	7/22/25
Time:	1:30 PM
Method:	Grab

Sample Final Analysis

Date:	7/25/25
Time:	10:00 AM
Analyst:	AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	7/23/25	11:00 AM	AH	SM 9222G
Total coliforms:	0/100mls	2/100mls	7/23/25	11:00 AM	AH	SM 9222B
Standard plate count:	0/ml	200/ml	7/22/25	5:00 PM	SL	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.0 SU	7.2 - 7.8 SU	7/22/25	1:30 PM	LM	DPD
Chlorine:	10.0 mg/l	1.0 - 5.0 mg/l	7/22/25	1:30 PM	LM	DPD
Turbidity:	1 NTU	1 - 2 NTU	7/22/25	1:30 PM	LM	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor

Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

C-11

Lab# 155

Customer

Facility Name: *Holiday Inn*

Address: *20 S 10th St.*
Pittsburgh, PA 15203

Matrix: *Recreational Water*

Source Type: *Pool*

Sample Collection

Date: 7/22/25
Time: 1:30 PM
Method: Grab

## Sample Final Analysis

Date: 7/25/25
Time: 10:00 AM
Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	7/23/25	11:00 AM	AH	SM 9222G
Total coliforms:	0/100mls	2/100mls	7/23/25	11:00 AM	AH	SM 9222B
Standard plate count:	0/ml	200/ml	7/22/25	5:00 PM	SL	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.0 SU	7.2 - 7.8 SU	7/22/25	1:30 PM	LM	DPD
Chlorine:	10.0 mg/l	1.0 - 5.0 mg/l	7/22/25	1:30 PM	LM	DPD
Turbidity:	1 NTU	1 - 2 NTU	7/22/25	1:30 PM	LM	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith

Andre Smith, Lead Supervisor