



Dream Pools And Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

APM 2

Lab# 2141

Customer

American Pools Management
3261 Babcock Blvd.
Pittsburgh, PA 15237

Sample Collection

Facility Name: Crane Village

Date: 6/23/25

Address: 651 Oaklynn Court
Pittsburgh, PA 15220

Time: 2:22 PM

Method: Grab

Matrix: Recreational Water

Sample Final Analysis

Date: 6/26/25

Source Type: Pool

Time: 9:00 AM

Analyst: AS

| Accredited Analysis | Results | Reporting limit | Incubation Date/Time | | Analyst | Method |
|----------------------------|----------------|------------------------|-----------------------------|----------|----------------|---------------|
| Escherichia Coli: | Absent | Absent | 6/24/25 | 10:40 AM | EB | SM 9222G |
| Total coliforms: | 0/100mls | 2/100mls | 6/24/25 | 10:40 AM | EB | SM 9222B |
| Standard plate count: | 0/ml | 200/ml | 6/23/25 | 6:00 PM | EB | SM 9215B |
| Field Analysis | Results | Reporting limit | Date/Time | | Analyst | Method |
| pH: | 7.2 SU | 7.2 - 7.8 SU | 6/23/25 | 2:22 PM | CW | DPD |
| Chlorine: | 3.0 mg/l | 1.0 - 5.0 mg/l | 6/23/25 | 2:22 PM | CW | DPD |
| Turbidity: | 1 NTU | 1 - 2 NTU | 6/23/25 | 2:22 PM | CW | Visual |

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor



Dream Pools And Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

APM 2

Lab# 2141

Customer

American Pools Management
3261 Babcock Blvd.
Pittsburgh, PA 15237

Sample Collection

Facility Name: Crane Village

Date: 6/23/25

Address: 651 Oaklynn Court
Pittsburgh, PA 15220

Time: 2:22 PM

Method: Grab

Matrix: Recreational Water

Sample Final Analysis

Date: 6/26/25

Source Type: Pool

Time: 9:00 AM

Analyst: AS

| Accredited Analysis | Results | Reporting limit | Incubation Date/Time | | Analyst | Method |
|----------------------------|----------------|------------------------|-----------------------------|----------|----------------|---------------|
| Escherichia Coli: | Absent | Absent | 6/24/25 | 10:40 AM | EB | SM 9222G |
| Total coliforms: | 0/100mls | 2/100mls | 6/24/25 | 10:40 AM | EB | SM 9222B |
| Standard plate count: | 0/ml | 200/ml | 6/23/25 | 6:00 PM | EB | SM 9215B |
| Field Analysis | Results | Reporting limit | Date/Time | | Analyst | Method |
| pH: | 7.2 SU | 7.2 - 7.8 SU | 6/23/25 | 2:22 PM | CW | DPD |
| Chlorine: | 3.0 mg/l | 1.0 - 5.0 mg/l | 6/23/25 | 2:22 PM | CW | DPD |
| Turbidity: | 1 NTU | 1 - 2 NTU | 6/23/25 | 2:22 PM | CW | Visual |

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor