



Dream Pools And Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

APM 2

Lab# 2726

Customer *American Pools Management*
3261 Babcock Blvd.
Pittsburgh, PA 15237

Sample Collection

Facility Name: *Felson Apts*

Date: *7/21/25*

Address: *8000 Brandt Dr.*
Cranberry, PA 16066

Time: *2:00 PM*

Method: *Grab*

Sample Final Analysis

Matrix: *Recreational Water*

Date: *7/24/25*

Source Type: *Pool*

Time: *10:00 AM*

Analyst: *AS*

Accredited Analysis	Results	Reporting limit	Incubation	Date/Time	Analyst	Method
Escherichia Coli:	Absent	Absent	7/22/25	10:00 AM	AH	SM 9222G
Total coliforms:	0/100mls	2/100mls	7/22/25	10:00 AM	AH	SM 9222B
Standard plate count:	0/ml	200/ml	7/21/25	5:00 PM	AH	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time	Analyst	Method	
pH:	7.8 SU	7.2 - 7.8 SU	7/21/25	2:00 PM	ZR	DPD
Chlorine:	10.0 mg/l	1.0 - 5.0 mg/l	7/21/25	2:00 PM	ZR	DPD
Turbidity:	1 NTU	1 - 2 NTU	7/21/25	2:00 PM	ZR	Visual

Sample comments

Andre Smith

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor



Dream Pools And Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

APM 2

Lab# 2726

Customer *American Pools Management*
3261 Babcock Blvd.
Pittsburgh, PA 15237

Sample Collection

Facility Name: *Felson Apts* *Date:* *7/21/25*
Address: *8000 Brandt Dr.* *Time:* *2:00 PM*
Cranberry, PA 16066 *Method:* *Grab*

Sample Final Analysis

Matrix: *Recreational Water* *Date:* *7/24/25*
Source Type: *Pool* *Time:* *10:00 AM*
Analyst: *AS*

Accredited Analysis	Results	Reporting limit	Incubation Date/Time	Analyst	Method
Escherichia Coli:	Absent	Absent	7/22/25 10:00 AM	AH	SM 9222G
Total coliforms:	0/100mls	2/100mls	7/22/25 10:00 AM	AH	SM 9222B
Standard plate count:	0/ml	200/ml	7/21/25 5:00 PM	AH	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time	Analyst	Method
pH:	7.8 SU	7.2 - 7.8 SU	7/21/25 2:00 PM	ZR	DPD
Chlorine:	10.0 mg/l	1.0 - 5.0 mg/l	7/21/25 2:00 PM	ZR	DPD
Turbidity:	1 NTU	1 - 2 NTU	7/21/25 2:00 PM	ZR	Visual

Sample comments

Andre Smith

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor