



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661-7665
Laboratory Analysis Report

Lab ID No. 02-04041

E-3

Lab# 477

<u>Customer</u>		<u>Sample Collection</u>	
Facility Name:	Comfort Inn Duncansville	Date:	9/22/25
Address:	130 Patchway Rd. Duncansville, PA 16635	Time:	12:40 PM
Matrix:	Recreational Water	Method:	Grab
Source Type:	Pool		
<u>Accredited Analysis</u>		<u>Results</u>	<u>Reporting limit</u>
Escherichia Coli:	Absent	Absent	9/23/25
Total coliforms:	0/100mls	2/100mls	9/23/25
Standard plate count:	0/ml	200/ml	9/22/25
10:00 AM	JC	SM 9222G	
10:00 AM	JC	SM 9222B	
5:30 PM	SL	SM 9215B	

<u>Field Analysis</u>	<u>Results</u>	<u>Reporting limit</u>	<u>Date/Time</u>	<u>Analyst</u>	<u>Method</u>
pH:	7.8 SU	7.2 - 7.8 SU	9/22/25	12:40 PM	DNP
Chlorine:	7.5 mg/l	1.0 - 5.0 mg/l	9/22/25	12:40 PM	DNP
Turbidity:	1 NTU	1 - 2 NTU	9/22/25	12:40 PM	DNP
					Visual

Sample comments

Andre Smith

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor