Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

S-12

Lab# 2303

Customer

Facility Name:	*Kennywood Park*
Address:	*4800 Kennywood Blvd.*
	West Mifflin, PA 15122
Matrix:	*Recreational Water*
Source Type:	*Raging Rapids*

Sample Collection

Date:	*8/12/25*
Time:	8:00 AM
Method:	*Grab*

Sample Final Analysis

Date:	*8/15/25*
Time:	*9:00 AM*
Analyst:	*AS*

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	8/13/25	10:30 AM	EB	SM 9222G
Total coliforms:	0/100mls	2/100mls	8/13/25	10:30 AM	EB	SM 9222B
Standard plate count:	5700/ml	200/ml	8/12/25	5:00 PM	SL	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	8.0 SU	7.2 - 7.8 SU	8/12/25	8:00 AM	BL	DPD
Chlorine:	3.0 mg/l	1.0 - 5.0 mg/l	8/12/25	8:00 AM	BL	DPD
Turbidity:	1 NTU	1 - 2 NTU	8/12/25	8:00 AM	BL	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith

_____

Andre Smith, Lead Supervisor

	Dream Pools and Spas	Lab ID No. 02-04041
	1105 Washington Blvd	
	Pittsburgh, Pennsylvania 15206	**S-12**
	(412) 661- 7665	
	Laboratory Analysis Report	**Lab# 2303**

Customer			**Sample Collection**	
Facility Name:	*Kennywood Park*		*Date:*	*8/12/25*
			Time:	*8:00 AM*
Address:	*4800 Kennywood Blvd.*		*Method:*	*Grab*
	West Mifflin, PA 15122			
			Sample Final Analysis	
Matrix:	*Recreational Water*		*Date:*	*8/15/25*
			Time:	*9:00 AM*
Source Type:	*Raging Rapids*		*Analyst:*	*AS*

Accredited Analysis	**Results**	**Reporting limit**	**Incubation Date/Time**		**Analyst**	**Method**
Escherichia Coli:	Absent	Absent	8/13/25	10:30 AM	EB	SM 9222G
Total coliforms:	0/100mls	2/100mls	8/13/25	10:30 AM	EB	SM 9222B
Standard plate count:	5700/ml	200/ml	8/12/25	5:00 PM	SL	SM 9215B

Field Analysis	**Results**	**Reporting limit**	**Date/Time**		**Analyst**	**Method**
pH:	8.0 SU	7.2 - 7.8 SU	8/12/25	8:00 AM	BL	DPD
Chlorine:	3.0 mg/l	1.0 - 5.0 mg/l	8/12/25	8:00 AM	BL	DPD
Turbidity:	1 NTU	1 - 2 NTU	8/12/25	8:00 AM	BL	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

andre Smith

_____

Andre Smith, Lead Supervisor