



**Dream Pools and Spas**  
**1105 Washington Blvd**  
**Pittsburgh, Pennsylvania 15206**  
**(412) 661- 7665**  
**Laboratory Analysis Report**

Lab ID No. 02-04041

**E - 11**

**Lab# 2499**

**Customer**

Facility Name: Southwind

Address: 777 Waterwheel Dr.  
Champion, PA 15622

Matrix: Recreational Water

Source Type: Pool

**Sample Collection**

Date: 6/30/25

Time: 11:07 AM

Seven Sprin Method: Grab

**Sample Final Analysis**

Date: 7/3/25

Time: 9:30 AM

Analyst: 1/0/00

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	7/1/25	10:00 AM	EB	SM 9222G
Total coliforms:	0/100mls	2/100mls	7/1/25	10:00 AM	EB	SM 9222B
Standard plate count:	0/ml	200/ml	6/30/25	4:10 PM	EB	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.4 SU	7.2 - 7.8 SU	6/30/25	11:07 AM	JC	DPD
Chlorine:	10.0 mg/l	1.0 - 5.0 mg/l	6/30/25	11:07 AM	JC	DPD
Turbidity:	1 NTU	1 - 2 NTU	6/30/25	11:07 AM	JC	Visual

**Sample comments**

( When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor



**Dream Pools and Spas**  
**1105 Washington Blvd**  
**Pittsburgh, Pennsylvania 15206**  
**(412) 661- 7665**  
**Laboratory Analysis Report**

Lab ID No. 02-04041

**E - 11**

**Lab# 2499**

**Customer**

Facility Name: Southwind

Address: 777 Waterwheel Dr.  
Champion, PA 15622

Matrix: Recreational Water

Source Type: Pool

**Sample Collection**

Date: 6/30/25

Time: 11:07 AM

Seven Sprin Method: Grab

**Sample Final Analysis**

Date: 7/3/25

Time: 9:30 AM

Analyst: 1/0/00

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	7/1/25	10:00 AM	EB	SM 9222G
Total coliforms:	0/100mls	2/100mls	7/1/25	10:00 AM	EB	SM 9222B
Standard plate count:	0/ml	200/ml	6/30/25	4:10 PM	EB	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.4 SU	7.2 - 7.8 SU	6/30/25	11:07 AM	JC	DPD
Chlorine:	10.0 mg/l	1.0 - 5.0 mg/l	6/30/25	11:07 AM	JC	DPD
Turbidity:	1 NTU	1 - 2 NTU	6/30/25	11:07 AM	JC	Visual

**Sample comments**

( When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor