

## Dream Pools And Spas 1105 Washington Blvd Pittsburgh, Pennsylvania 15206 (412) 661- 7665 Laboratory Analysis Report

Lab ID No. 02-04041

APM 2

Lab# 2255

<u>Customer</u> American Pools Management

3261 Babcock Blvd. Pittsburgh, PA 15237

Facility Name: Highfield Crossing

Address: 1200 Highfield Ct.

Bethel Park, PA 15102

Matrix: Recreational Water

Source Type: Pool

Sample Collection

Date: 6/24/25 Time: 11:05 AM

Method: Grab

Sample Final Analysis

 Date:
 6/27/25

 Time:
 9:20 AM

Time: 9:20 AM Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	6/25/25	10:15 AM	EB	SM 9222G
Total coliforms:	0/100mls	2/100mls	6/25/25	10:15 AM	EB	SM 9222B
Standard plate count:	200/ml	200/ml	6/24/25	3:59 PM	АН	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
рН:	7.6 SU	7.2 - 7.8 SU	6/24/25	11:05 AM	CW	DPD
Chlorine:	2.0 mg/l	1.0 - 5.0 mg/l	6/24/25	11:05 AM	CW	DPD
Turbidity:	1 NTU	1 - 2 NTU	6/24/25	11:05 AM	CW	Visual

## Sample comments

anobie Smith

( When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor



## Dream Pools And Spas 1105 Washington Blvd Pittsburgh, Pennsylvania 15206 (412) 661- 7665 Laboratory Analysis Report

Lab ID No. 02-04041

APM 2

Lab# 2255

<u>Customer</u> American Pools Management

3261 Babcock Blvd. Pittsburgh, PA 15237

Facility Name: Highfield Crossing

Address: 1200 Highfield Ct.

Bethel Park, PA 15102

Matrix: Recreational Water

Source Type: Pool

Sample Collection

Date: 6/24/25 Time: 11:05 AM

Method: Grab

Sample Final Analysis

 Date:
 6/27/25

 Time:
 9:20 AM

Time: 9:20 AM Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	6/25/25	10:15 AM	EB	SM 9222G
Total coliforms:	0/100mls	2/100mls	6/25/25	10:15 AM	EB	SM 9222B
Standard plate count:	200/ml	200/ml	6/24/25	3:59 PM	АН	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
рН:	7.6 SU	7.2 - 7.8 SU	6/24/25	11:05 AM	CW	DPD
Chlorine:	2.0 mg/l	1.0 - 5.0 mg/l	6/24/25	11:05 AM	CW	DPD
Turbidity:	1 NTU	1 - 2 NTU	6/24/25	11:05 AM	CW	Visual

## Sample comments

anobie Smith

( When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor