



Dream Pools And Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

APM 1

Lab# 2064

Customer

American Pools Management
3261 Babcock Blvd.
Pittsburgh, PA 15237

Sample Collection

Facility Name: Brook Park Swim Club

Date: 7/8/25

Address: 8190 Rochester Rd
Pittsburgh, PA 15237

Time: 1:16 PM

Method: Grab

Sample Final Analysis

Matrix: Recreational Water

Date: 7/11/25

Source Type: Wading Pool

Time: 9:00 AM

Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation	Date/Time	Analyst	Method
Escherichia Coli:	Absent	Absent	7/9/25	10:40 AM	EB	SM 9222G
Total coliforms:	0/100mls	2/100mls	7/9/25	10:40 AM	EB	SM 9222B
Standard plate count:	0/ml	200/ml	7/8/25	5:35 PM	AS	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time	Analyst	Method	
pH:	7.8 SU	7.2 - 7.8 SU	7/8/25	1:16 PM	MM	DPD
Chlorine:	3.0 mg/l	1.0 - 5.0 mg/l	7/8/25	1:16 PM	MM	DPD
Turbidity:	1 NTU	1 - 2 NTU	7/8/25	1:16 PM	MM	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith

Andre Smith, Lead Supervisor



Dream Pools And Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

APM 1

Lab# 2064

Customer

American Pools Management
3261 Babcock Blvd.
Pittsburgh, PA 15237

Sample Collection

Facility Name: Brook Park Swim Club

Date: 7/8/25

Address: 8190 Rochester Rd
Pittsburgh, PA 15237

Time: 1:16 PM

Method: Grab

Sample Final Analysis

Matrix: Recreational Water

Date: 7/11/25

Source Type: Wading Pool

Time: 9:00 AM

Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation	Date/Time	Analyst	Method
Escherichia Coli:	Absent	Absent	7/9/25	10:40 AM	EB	SM 9222G
Total coliforms:	0/100mls	2/100mls	7/9/25	10:40 AM	EB	SM 9222B
Standard plate count:	0/ml	200/ml	7/8/25	5:35 PM	AS	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time	Analyst	Method	
pH:	7.8 SU	7.2 - 7.8 SU	7/8/25	1:16 PM	MM	DPD
Chlorine:	3.0 mg/l	1.0 - 5.0 mg/l	7/8/25	1:16 PM	MM	DPD
Turbidity:	1 NTU	1 - 2 NTU	7/8/25	1:16 PM	MM	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith

Andre Smith, Lead Supervisor