

Dream Pools and Spas 1105 Washington Blvd Pittsburgh, Pennsylvania 15206 (412) 661- 7665 Laboratory Analysis Report

Lab ID No. 02-04041

W-12

Lab# 2098

7/9/25

<u>Customer</u> <u>Sample Collection</u>

Facility Name: Chartiers Valley C.C. Date:

Address: 601 Baldwin Road Time: 9:30 AM

Method: Grab

Pittsburgh, PA 15205

Matrix: Recreational Water Sample Final Analysis

Date: 7/12/25

Source Type: Shallow End Time: 8:30 AM
Analyst: AS

Accredited Analysis Results Reporting limit **Incubation Date/Time Analyst** Method Escherichia Coli: Absent 7/9/25 3:30 PM ΕB Absent SM 9222G Total coliforms: 0/100mls 2/100mls 7/9/25 3:30 PM EΒ SM 9222B SM 9215B Standard plate count: 0/ml 200/ml 7/9/25 3:00 PM AΗ

Field Analysis	Results	Reporting limit		Date/Time	Analyst	Method
pH:	7.4 SU	7.2 - 7.8 SU	7/9/25	9:30 AM	VH	DPD
Chlorine:	5.0 mg/l	1.0 - 5.0 mg/l	7/9/25	9:30 AM	VH	DPD
Turbidity:	1 NTU	1 - 2 NTU	7/9/25	9:30 AM	VH	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

andre Smith

Andre Smith, Lead Supervisor



Dream Pools and Spas 1105 Washington Blvd Pittsburgh, Pennsylvania 15206 (412) 661- 7665 Laboratory Analysis Report

Lab ID No. 02-04041

W-12

Lab# 2098

7/9/25

<u>Customer</u> <u>Sample Collection</u>

Facility Name: Chartiers Valley C.C. Date:

Address: 601 Baldwin Road Time: 9:30 AM

Method: Grab

Pittsburgh, PA 15205

Matrix: Recreational Water Sample Final Analysis

Date: 7/12/25

Source Type: Shallow End Time: 8:30 AM
Analyst: AS

Accredited Analysis Results Reporting limit **Incubation Date/Time Analyst** Method Escherichia Coli: Absent 7/9/25 3:30 PM ΕB Absent SM 9222G Total coliforms: 0/100mls 2/100mls 7/9/25 3:30 PM EΒ SM 9222B SM 9215B Standard plate count: 0/ml 200/ml 7/9/25 3:00 PM AΗ

Field Analysis	Results	Reporting limit		Date/Time	Analyst	Method
pH:	7.4 SU	7.2 - 7.8 SU	7/9/25	9:30 AM	VH	DPD
Chlorine:	5.0 mg/l	1.0 - 5.0 mg/l	7/9/25	9:30 AM	VH	DPD
Turbidity:	1 NTU	1 - 2 NTU	7/9/25	9:30 AM	VH	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

andre Smith

Andre Smith, Lead Supervisor