



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

APM 4

Lab# 2553

Customer *American Pools Management
3261 Babcock Blvd.
Pittsburgh, PA 15237*

Facility Name: *Village of Sewickley Hills*

Sample Collection

Date: 7/2/25

Address: *104 Prescott Place
Sewickley, PA 15143*

Time: 11:15 AM

Method: Grab

Matrix: *Recreational Water*

Sample Final Analysis

Date: 7/4/25

Source Type: *Pool*

Time: 3:30 PM

Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time	Analyst	Method
Escherichia Coli:	Absent	Absent	7/2/25	6:00 PM	SL SM 9222G
Total coliforms:	0/100mls	2/100mls	7/2/25	6:00 PM	SL SM 9222B
Standard plate count:	0/ml	200/ml	7/2/25	5:50 PM	SL SM 9215B

Field Analysis	Results	Reporting limit	Date/Time	Analyst	Method
pH:	8.0 SU	7.2 - 7.8 SU	7/2/25	11:15 AM	VH DPD
Chlorine:	10.0 mg/l	1.0 - 5.0 mg/l	7/2/25	11:15 AM	VH DPD
Turbidity:	1 NTU	1 - 2 NTU	7/2/25	11:15 AM	VH Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

A handwritten signature in black ink that reads "Andre Smith".

Andre Smith, Lead Supervisor



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

APM 4

Lab# 2553

Customer *American Pools Management
3261 Babcock Blvd.
Pittsburgh, PA 15237*

Facility Name: *Village of Sewickley Hills*

Sample Collection

Date: 7/2/25

Address: *104 Prescott Place
Sewickley, PA 15143*

Time: 11:15 AM

Method: Grab

Matrix: *Recreational Water*

Sample Final Analysis

Date: 7/4/25

Source Type: *Pool*

Time: 3:30 PM

Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time	Analyst	Method
Escherichia Coli:	Absent	Absent	7/2/25	6:00 PM	SL SM 9222G
Total coliforms:	0/100mls	2/100mls	7/2/25	6:00 PM	SL SM 9222B
Standard plate count:	0/ml	200/ml	7/2/25	5:50 PM	SL SM 9215B

Field Analysis	Results	Reporting limit	Date/Time	Analyst	Method
pH:	8.0 SU	7.2 - 7.8 SU	7/2/25	11:15 AM	VH DPD
Chlorine:	10.0 mg/l	1.0 - 5.0 mg/l	7/2/25	11:15 AM	VH DPD
Turbidity:	1 NTU	1 - 2 NTU	7/2/25	11:15 AM	VH Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

A handwritten signature in black ink that reads "Andre Smith".

Andre Smith, Lead Supervisor