



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

N-12

Lab# 2187

Customer

Facility Name: *Fields of Nicholson*
Address: *1719 Waterleaf Dr.*
Franklin Park, PA 15143

Matrix: *Recreational Water*

Source Type: *Pool*

Sample Collection

Date: *7/2/25*
Time: *11:48 AM*
Method: *Grab*

Sample Final Analysis

Date: *7/4/25*
Time: *3:30 PM*
Analyst: *AS*

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	7/2/25	6:00 PM	SL	SM 9222G
Total coliforms:	0/100mls	2/100mls	7/2/25	6:00 PM	SL	SM 9222B
Standard plate count:	5700/ml	200/ml	7/2/25	5:50 PM	SL	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.2 SU	7.2 - 7.8 SU	7/2/25	11:48 AM	CW	DPD
Chlorine:	2.0 mg/l	1.0 - 5.0 mg/l	7/2/25	11:48 AM	CW	DPD
Turbidity:	1 NTU	1 - 2 NTU	7/2/25	11:48 AM	CW	Visual

Sample comments

Andre Smith

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

N-12

Lab# 2187

Customer

Facility Name: *Fields of Nicholson*
Address: *1719 Waterleaf Dr.*
Franklin Park, PA 15143

Matrix: *Recreational Water*

Source Type: *Pool*

Sample Collection

Date: *7/2/25*
Time: *11:48 AM*
Method: *Grab*

Sample Final Analysis

Date: *7/4/25*
Time: *3:30 PM*
Analyst: *AS*

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	7/2/25	6:00 PM	SL	SM 9222G
Total coliforms:	0/100mls	2/100mls	7/2/25	6:00 PM	SL	SM 9222B
Standard plate count:	5700/ml	200/ml	7/2/25	5:50 PM	SL	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.2 SU	7.2 - 7.8 SU	7/2/25	11:48 AM	CW	DPD
Chlorine:	2.0 mg/l	1.0 - 5.0 mg/l	7/2/25	11:48 AM	CW	DPD
Turbidity:	1 NTU	1 - 2 NTU	7/2/25	11:48 AM	CW	Visual

Sample comments

Andre Smith

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor