



**Dream Pools and Spas**  
**1105 Washington Blvd**  
**Pittsburgh, Pennsylvania 15206**  
**(412) 661- 7665**  
**Laboratory Analysis Report**

Lab ID No. 02-04041

**N - 1**

**Lab# 437**

**Customer**

**Facility Name:** Grove City College  
**Address:** 100 Campus Dr.  
Grove City, PA 16127

**Matrix:** Recreational Water

**Source Type:** Rec Pool

**Sample Collection**

**Date:** 11/3/25  
**Time:** 1:40 PM  
**Method:** Grab

**Sample Final Analysis**

**Date:** 11/6/25  
**Time:** 11:00 AM  
**Analyst:** AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	11/4/25	10:30 AM	JC	SM 9222G
Total coliforms:	0/100mls	2/100mls	11/4/25	10:30 AM	JC	SM 9222B
Standard plate count:	0/ml	200/ml	11/3/25	5:30 PM	SL	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.6 SU	7.2 - 7.8 SU	11/3/25	1:40 PM	BH	DPD
Chlorine:	5.0 mg/l	1.0 - 5.0 mg/l	11/3/25	1:40 PM	BH	DPD
Turbidity:	1 NTU	1 - 2 NTU	11/3/25	1:40 PM	BH	Visual

**Sample comments**

( When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor