



**Dream Pools and Spas**  
**1105 Washington Blvd**  
**Pittsburgh, Pennsylvania 15206**  
**(412) 661- 7665**  
**Laboratory Analysis Report**

Lab ID No. 02-04041

**S-1**

**Lab# 318**

**Customer**

Facility Name: Upper St. Clair Rec.  
Address: 1551 Mayview Road  
Upper St. Clair, PA 15241

**Sample Collection**

Date: 9/3/25  
Time: 3:13 PM  
Method: Grab

Matrix: Recreational Water

Source Type: Lap Pool Deep

**Sample Final Analysis**

Date: 9/6/25  
Time: 2:00 PM  
Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	9/4/25	10:15 AM	JC	SM 9222G
Total coliforms:	0/100mls	2/100mls	9/4/25	10:15 AM	JC	SM 9222B
Standard plate count:	0/ml	200/ml	9/3/25	6:00 PM	SL	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.4 SU	7.2 - 7.8 SU	9/3/25	3:13 PM	MM	DPD
Chlorine:	3.0 mg/l	1.0 - 5.0 mg/l	9/3/25	3:13 PM	MM	DPD
Turbidity:	1 NTU	1 - 2 NTU	9/3/25	3:13 PM	MM	Visual

**Sample comments**

( When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor