



**Dream Pools and Spas**  
**1105 Washington Blvd**  
**Pittsburgh, Pennsylvania 15206**  
**(412) 661- 7665**  
**Laboratory Analysis Report**

Lab ID No. 02-04041

**E-2**

**Lab# 223**

**Customer**

Facility Name: *McKeesport High School*

Address: *1960 Eden Park Blvd.  
McKeesport, PA 15132*

Matrix: *Recreational Water*

Source Type: *Pool Deep*

**Sample Collection**

Date: *12/8/25*

Time: *3:12 PM*

Method: *Grab*

**Sample Final Analysis**

Date: *12/11/25*

Time: *10:30 AM*

Analyst: *AS*

Accredited Analysis	Results	Reporting limit	Incubation	Date/Time	Analyst	Method
Escherichia Coli:	Absent	Absent	12/9/25	10:10 AM	JC	SM 9222G
Total coliforms:	0/100mls	2/100mls	12/9/25	10:10 AM	JC	SM 9222B
Standard plate count:	0/ml	200/ml	12/8/25	5:00 PM	SL	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time	Analyst	Method	
pH:	8.0 SU	7.2 - 7.8 SU	12/8/25	3:12 PM	JC	DPD
Chlorine:	1.0 mg/l	1.0 - 5.0 mg/l	12/8/25	3:12 PM	JC	DPD
Turbidity:	1 NTU	1 - 2 NTU	12/8/25	3:12 PM	JC	Visual

**Sample comments**

( When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor