



Lab ID No. 02-04041

**Dream Pools and Spas**  
**1105 Washington Blvd**  
**Pittsburgh, Pennsylvania 15206**  
**(412) 661- 7665**  
**Laboratory Analysis Report**

**Service****Lab# 312****Customer****Facility Name:** UPMC Lemieux Sports Complex**Address:** 8000 Cranberry Springs Drive  
Cranberry Township, PA 16066**Matrix:** Recreational Water**Source Type:** Cold Plunge**Sample Collection****Date:** 4/29/25**Time:** 9:45 AM**Method:** Grab**Sample Final Analysis****Date:** 5/2/25**Time:** 9:30 AM**Analyst:** AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	4/30/25	11:00 AM	PS	SM 9222G
Total coliforms:	0/100mls	2/100mls	4/30/25	11:00 AM	PS	SM 9222B
Standard plate count:	0/ml	200/ml	4/29/25	5:00 PM	AS	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	8.0 SU	7.2 - 7.8 SU	4/29/25	9:45 AM	JR	DPD
Chlorine:	5.0 mg/l	1.0 - 5.0 mg/l	4/29/25	9:45 AM	JR	DPD
Turbidity:	1 NTU	1 - 2 NTU	4/29/25	9:45 AM	JR	Visual

**Sample comments**

( When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor



Lab ID No. 02-04041

**Dream Pools and Spas**  
**1105 Washington Blvd**  
**Pittsburgh, Pennsylvania 15206**  
**(412) 661- 7665**  
**Laboratory Analysis Report**

**Service****Lab# 312****Customer****Facility Name:** UPMC Lemieux Sports Complex**Address:** 8000 Cranberry Springs Drive  
Cranberry Township, PA 16066**Matrix:** Recreational Water**Source Type:** Cold Plunge**Sample Collection****Date:** 4/29/25**Time:** 9:45 AM**Method:** Grab**Sample Final Analysis****Date:** 5/2/25**Time:** 9:30 AM**Analyst:** AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	4/30/25	11:00 AM	PS	SM 9222G
Total coliforms:	0/100mls	2/100mls	4/30/25	11:00 AM	PS	SM 9222B
Standard plate count:	0/ml	200/ml	4/29/25	5:00 PM	AS	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	8.0 SU	7.2 - 7.8 SU	4/29/25	9:45 AM	JR	DPD
Chlorine:	5.0 mg/l	1.0 - 5.0 mg/l	4/29/25	9:45 AM	JR	DPD
Turbidity:	1 NTU	1 - 2 NTU	4/29/25	9:45 AM	JR	Visual

**Sample comments**

( When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor