



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

W-1

Lab# 362

Customer

Facility Name: YMCA - Sewickley
Address: 625 Blackburn Rd.
Sewickley, PA 15143

Matrix: Recreational Water
Source Type: Deep End

Sample Collection

Date: 10/6/25
Time: 4:03 PM
Method: Grab

Sample Final Analysis

Date: 10/9/25
Time: 11:00 AM
Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time	Analyst	Method
Escherichia Coli:	Absent	Absent	10/7/25 11:30 AM	AS	SM 9222G
Total coliforms:	0/100mls	2/100mls	10/7/25 11:30 AM	AS	SM 9222B
Standard plate count:	0/ml	200/ml	10/6/25 5:30 PM	AS	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time	Analyst	Method
pH:	7.4 SU	7.2 - 7.8 SU	10/6/25 4:03 PM	SL	DPD
Chlorine:	2.0 mg/l	1.0 - 5.0 mg/l	10/6/25 4:03 PM	SL	DPD
Turbidity:	1 NTU	1 - 2 NTU	10/6/25 4:03 PM	SL	Visual

Sample comments

Andre Smith

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor