

Dream Pools and Spas 1105 Washington Blvd Pittsburgh, Pennsylvania 15206 (412) 661-7665 **Laboratory Analysis Report**

Lab ID No. 02-04041

W-11

Lab# 2727

Customer

Facility Name: Montour CC

1491 Coraopolis Heights Rd Address:

Coraopolis, PA 15108

Matrix: Recreational Water

Source Type: Deep End Sample Collection

Date:

7/22/25 Time: 12:00 PM

Method: Grab

Sample Final Analysis 7/25/25

Date: Time:

10:00 AM

Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	7/23/25	9:20 AM	АН	SM 9222G
Total coliforms:	0/100mls	2/100mls	7/23/25	9:20 AM	АН	SM 9222B
Standard plate count:	0/ml	200/ml	7/22/25	3:40 PM	SL	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.4 SU	7.2 - 7.8 SU	7/22/25	12:00 PM	VH	DPD
Chlorine:	5.0 mg/l	1.0 - 5.0 mg/l	7/22/25	12:00 PM	VH	DPD
Turbidity:	1 NTU	1 - 2 NTU	7/22/25	12:00 PM	VH	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

andre Smith



Dream Pools and Spas 1105 Washington Blvd Pittsburgh, Pennsylvania 15206 (412) 661-7665 **Laboratory Analysis Report**

Lab ID No. 02-04041

W-11

Lab# 2727

Customer

Facility Name: Montour CC

1491 Coraopolis Heights Rd Address:

Coraopolis, PA 15108

Matrix: Recreational Water

Source Type: Deep End Sample Collection

Date:

7/22/25 Time: 12:00 PM

Method: Grab

Sample Final Analysis 7/25/25

Date: Time:

10:00 AM

Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	7/23/25	9:20 AM	АН	SM 9222G
Total coliforms:	0/100mls	2/100mls	7/23/25	9:20 AM	АН	SM 9222B
Standard plate count:	0/ml	200/ml	7/22/25	3:40 PM	SL	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.4 SU	7.2 - 7.8 SU	7/22/25	12:00 PM	VH	DPD
Chlorine:	5.0 mg/l	1.0 - 5.0 mg/l	7/22/25	12:00 PM	VH	DPD
Turbidity:	1 NTU	1 - 2 NTU	7/22/25	12:00 PM	VH	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

andre Smith