



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661-7665
Laboratory Analysis Report

Service

Lab# 379

Customer

Facility Name: PPG Paints Arena

Sample Collection

Date: 12/2/24

Address: 1001 Fifth Ave
Pittsburgh, PA 15219

Time: 11:00 AM

Method: Grab

Matrix: Recreational Water

Sample Final Analysis

Date: 12/5/24

Source Type: Spa

Time: 9:00 AM

Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time	Analyst	Method
Escherichia Coli:	Absent	Absent	12/3/24	9:30 AM	AS SM 9222G
Total coliforms:	0/100mls	2/100mls	12/3/24	9:30 AM	AS SM 9222B
Standard plate count:	0/ml	200/ml	12/2/24	5:15 PM	AS SM 9215B

Additional Analysis	Results	Reporting limit	Incubation Date/Time	Analyst	Method
Fecal Streptococcus	0/100mls	2/100mls	12/3/24	9:30 AM	AS SM 9230C

Field Analysis	Results	Reporting limit	Date/Time	Analyst	Method
pH:	7.6 SU	7.2 - 7.8 SU	12/2/24	11:00 AM	DS DPD
Chlorine:	3.0 mg/l	1.0 - 5.0 mg/l	12/2/24	11:00 AM	DS DPD
Turbidity:	1 NTU	1 - 2 NTU	12/2/24	11:00 AM	DS Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor