



**Dream Pools and Spas**  
**1105 Washington Blvd**  
**Pittsburgh, Pennsylvania 15206**  
**(412) 661- 7665**  
**Laboratory Analysis Report**

Lab ID No. 02-04041

**N-15**

**Lab# 2635**

**Customer**

Facility Name: Village Cranberry Woods Apt.

Address: 5001 Pendleton Way  
Cranberry, PA 16066

Matrix: Recreational Water

Source Type: Spa

**Sample Collection**

Date: 6/3/25

Time: 10:42 AM

Method: Grab

**Sample Final Analysis**

Date: 6/6/25

Time: 9:30 AM

Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time	Analyst	Method
---------------------	---------	-----------------	----------------------	---------	--------

Escherichia Coli:	Absent	Absent	6/4/25	9:50 AM	EB	SM 9222G
-------------------	--------	--------	--------	---------	----	----------

Total coliforms:	0/100mls	2/100mls	6/4/25	9:50 AM	EB	SM 9222B
------------------	----------	----------	--------	---------	----	----------

Standard plate count:	0/ml	200/ml	6/3/25	4:25 PM	SL	SM 9215B
-----------------------	------	--------	--------	---------	----	----------

Additional Analysis	Results	Reporting limit	Incubation Date/Time	Analyst	Method
---------------------	---------	-----------------	----------------------	---------	--------

Fecal Streptococcus	0/100mls	2/100mls	6/4/25	12:00 PM	AH	SM 9230C
---------------------	----------	----------	--------	----------	----	----------

Field Analysis	Results	Reporting limit	Date/Time	Analyst	Method
----------------	---------	-----------------	-----------	---------	--------

pH:	7.6 SU	7.2 - 7.8 SU	6/3/25	10:42 AM	ZR	DPD
-----	--------	--------------	--------	----------	----	-----

Chlorine:	2.0 mg/l	1.0 - 5.0 mg/l	6/3/25	10:42 AM	ZR	DPD
-----------	----------	----------------	--------	----------	----	-----

Turbidity:	1 NTU	1 - 2 NTU	6/3/25	10:42 AM	ZR	Visual
------------	-------	-----------	--------	----------	----	--------

**Sample comments**

*Andre Smith*

( When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor



**Dream Pools and Spas**  
**1105 Washington Blvd**  
**Pittsburgh, Pennsylvania 15206**  
**(412) 661- 7665**  
**Laboratory Analysis Report**

Lab ID No. 02-04041

**N-15**

**Lab# 2635**

**Customer**

**Facility Name:** Village Cranberry Woods Apt.

**Address:** 5001 Pendleton Way  
Cranberry, PA 16066

**Matrix:** Recreational Water

**Source Type:** Spa

**Sample Collection**

**Date:** 6/3/25

**Time:** 10:42 AM

**Method:** Grab

**Sample Final Analysis**

**Date:** 6/6/25

**Time:** 9:30 AM

**Analyst:** AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time	Analyst	Method
---------------------	---------	-----------------	----------------------	---------	--------

Escherichia Coli:	Absent	Absent	6/4/25	9:50 AM	EB	SM 9222G
-------------------	--------	--------	--------	---------	----	----------

Total coliforms:	0/100mls	2/100mls	6/4/25	9:50 AM	EB	SM 9222B
------------------	----------	----------	--------	---------	----	----------

Standard plate count:	0/ml	200/ml	6/3/25	4:25 PM	SL	SM 9215B
-----------------------	------	--------	--------	---------	----	----------

Additional Analysis	Results	Reporting limit	Incubation Date/Time	Analyst	Method
---------------------	---------	-----------------	----------------------	---------	--------

Fecal Streptococcus	0/100mls	2/100mls	6/4/25	12:00 PM	AH	SM 9230C
---------------------	----------	----------	--------	----------	----	----------

Field Analysis	Results	Reporting limit	Date/Time	Analyst	Method
----------------	---------	-----------------	-----------	---------	--------

pH:	7.6 SU	7.2 - 7.8 SU	6/3/25	10:42 AM	ZR	DPD
-----	--------	--------------	--------	----------	----	-----

Chlorine:	2.0 mg/l	1.0 - 5.0 mg/l	6/3/25	10:42 AM	ZR	DPD
-----------	----------	----------------	--------	----------	----	-----

Turbidity:	1 NTU	1 - 2 NTU	6/3/25	10:42 AM	ZR	Visual
------------	-------	-----------	--------	----------	----	--------

**Sample comments**

*Andre Smith*

( When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor