Lab ID No. 02-04041

Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Andre Smith, Lead Supervisor

C-2

Lab# 446

Customer		***Sample Collection***	
Facility Name:	*Comfort Inn*	*Date:*	*3/10/26*
		Time:	12:45 PM
Address:	*830 East Ohio St.*	*Method:*	*Grab*
	Pittsburgh, PA 15222		
		Sample Final Analysis	
Matrix:	*Recreational Water*	*Date:*	*3/13/26*
		Time:	*10:30 AM*
Source Type:	*Pool*	*Analyst:*	*AS*

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	3/11/26	10:00 AM	JC	SM 9222G
Total coliforms:	0/100mls	2/100mls	3/11/26	10:00 AM	JC	SM 9222B
Standard plate count:	570/ml	200/ml	3/10/26	5:20 PM	SL	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	8.0 SU	7.2 - 7.8 SU	3/10/26	12:45 PM	BH	DPD
Chlorine:	0.0 mg/l	1.0 - 5.0 mg/l	3/10/26	12:45 PM	BH	DPD
Turbidity:	1 NTU	1 - 2 NTU	3/10/26	12:45 PM	BH	Visual

Sample comments

Andre Smith

Andre Smith, Lead Supervisor