# Dream Pools and Spas
## 1105 Washington Blvd
## Pittsburgh, Pennsylvania 15206
## (412) 661- 7665
## Laboratory Analysis Report

**Lab ID No. 02-04041**

**C-1**

***Lab# 188***

**Customer**

*Facility Name:* *Jewish Community Cntr*

*Address:* *5738 Forbes Ave.*
*Pittsburgh, PA 15217*

*Matrix:* *Recreational Water*

*Source Type:* *Small Pool*

**Sample Collection**

*Date:* *3/11/26*
*Time:* 10:02 AM
*Method:* *Grab*

**Sample Final Analysis**

*Date:* *3/13/26*
*Time:* *5:30 PM*
*Analyst:* *AS*

| Accredited Analysis | Results | Reporting limit | Incubation Date/Time | | Analyst | Method |
|---|---|---|---|---|---|---|
| Escherichia Coli: | Absent | Absent | 3/11/26 | 5:00 PM | SL | SM 9222G |
| Total coliforms: | 0/100mls | 2/100mls | 3/11/26 | 5:00 PM | SL | SM 9222B |
| Standard plate count: | 0/ml | 200/ml | 3/11/26 | 4:05 PM | SL | SM 9215B |

| Field Analysis | Results | Reporting limit | Date/Time | | Analyst | Method |
|---|---|---|---|---|---|---|
| pH: | 7.6 SU | 7.2 - 7.8 SU | 3/11/26 | 10:02 AM | SL | DPD |
| Chlorine: | 3.0 mg/l | 1.0 - 5.0 mg/l | 3/11/26 | 10:02 AM | SL | DPD |
| Turbidity: | 1 NTU | 1 - 2 NTU | 3/11/26 | 10:02 AM | SL | Visual |

**Sample comments**

( When exceeding reporting limit pool or spa is unfit)

Andre Smith

Andre Smith, Lead Supervisor

Andre Smith, Lead Supervisor