Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

N - 1

Lab# 373

[redacted]

Customer

Facility Name: *Pine Richland H.S.*

Address: *700 Warrendale Rd.*
Gibsonia, PA 15044

Matrix: *Recreational Water*

Source Type: *Shallow End*

Sample Collection

Date: *3/16/26*

Time: 10:05 AM

Method: *Grab*

Sample Final Analysis

Date: *1/0/00*

Time: *12:00 AM*

Analyst: *1/0/00*

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	3/17/26	11:00 AM	SL	SM 9222G
Total coliforms:	0/100mls	2/100mls	3/17/26	11:00 AM	SL	SM 9222B
Standard plate count:	0/ml	200/ml	3/16/26	5:18 PM	SL	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	8.0 SU	7.2 - 7.8 SU	3/16/26	10:05 AM	BH	DPD
Chlorine:	5.0 mg/l	1.0 - 5.0 mg/l	3/16/26	10:05 AM	BH	DPD
Turbidity:	1 NTU	1 - 2 NTU	3/16/26	10:05 AM	BH	Visual

Sample comments

Andre Smith

Andre Smith, Lead Supervisor

(When exceeding reporting limit pool or spa is unfit)