Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

N - 1

Lab# 388

[redacted]

Customer

Facility Name: *Towne Place Suites*

Address: *2020 Cool Springs Dr.*
Cranberry Township, PA 16066

Matrix: *Recreational Water*

Source Type: *Pool*

Sample Collection

Date: *3/16/26*
Time: 11:15 AM
Method: *Grab*

Sample Final Analysis

Date: *1/0/00*
Time: *12:00 AM*
Analyst: *1/0/00*

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	3/17/26	11:00 AM	SL	SM 9222G
Total coliforms:	0/100mls	2/100mls	3/17/26	11:00 AM	SL	SM 9222B
Standard plate count:	0/ml	200/ml	3/16/26	5:18 PM	SL	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	8.0 SU	7.2 - 7.8 SU	3/16/26	11:15 AM	BH	DPD
Chlorine:	2.0 mg/l	1.0 - 5.0 mg/l	3/16/26	11:15 AM	BH	DPD
Turbidity:	1 NTU	1 - 2 NTU	3/16/26	11:15 AM	BH	Visual

Sample comments

Andre Smith

Andre Smith, Lead Supervisor

(When exceeding reporting limit pool or spa is unfit)