Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665

Service Lab ID No. 02-04041

Service Tech# 425

Laboratory Analysis Report

Facility Name: *Chatham University*

Address: *1 Woodland Rd.*
Pittsburgh, PA 15232

Matrix: *Recreational Water*

Source Type: *Pool Shallow*

Sample Collection
Date: *10/20/26*
Time: 1:00 PM
Method: *Grab*

Sample Final Analysis
Date: *10/23/26*
Time: *10:00 AM*
Analyst: *JC*

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	10/21/26	9:30 AM	JC	SM 9222G
Total coliforms:	0/100mls	2/100mls	10/21/26	9:30 AM	JC	SM 9222B
Standard plate count:	0/ml	200/ml	10/20/26	2:35 PM	MH	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.4 SU	7.2 - 7.8 SU	10/20/26	1:00 PM	MB	DPD
Chlorine:	3.4 mg/l	1.0 - 5.0 mg/l	10/20/26	1:00 PM	MB	DPD
Turbidity:	1 NTU	1 - 2 NTU	10/20/26	1:00 PM	MB	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith

Andre Smith, Lead Supervisor