**Dream Pools and Spas**
**1105 Washington Blvd**
**Pittsburgh, Pennsylvania 15206**
**(412) 661- 7665**

# Laboratory Analysis Report

**Lab ID No. 02-04041**

**E-3**

***Lab# 476***

***Customer***

*Facility Name:* *Comfort Suites*

*Address:* *140 Stroehman Dr.*
*Altoona, PA 16601*

*Matrix:* *Recreational Water*

*Source Type:* *Pool*

***Sample Collection***

*Date:* *10/20/26*
*Time:* 3:00 PM
*Method:* *Grab*

***Sample Final Analysis***

*Date:* *10/23/26*
*Time:* *10:00 AM*
*Analyst:* *JC*

| Accredited Analysis | Results | Reporting limit | Incubation Date/Time | | Analyst | Method |
|---|---|---|---|---|---|---|
| Escherichia Coli: | Absent | Absent | 10/21/26 | 9:55 AM | MH | SM 9222G |
| Total coliforms: | 0/100mls | 2/100mls | 10/21/26 | 9:55 AM | MH | SM 9222B |
| Standard plate count: | 0/ml | 200/ml | 10/20/26 | 6:00 PM | SL | SM 9215B |

| Field Analysis | Results | Reporting limit | Date/Time | | Analyst | Method |
|---|---|---|---|---|---|---|
| pH: | 7.6 SU | 7.2 - 7.8 SU | 10/20/26 | 3:00 PM | DNP | DPD |
| Chlorine: | 7.5 mg/l | 1.0 - 5.0 mg/l | 10/20/26 | 3:00 PM | DNP | DPD |
| Turbidity: | 1 NTU | 1 - 2 NTU | 10/20/26 | 3:00 PM | DNP | Visual |

**Sample comments**

Andre Smith

Andre Smith, Lead Supervisor

( When exceeding reporting limit pool or spa is unfit)