# Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
**Laboratory Analysis Report**

**Lab ID No. 02-04041**

**N-3**

***Lab# 227***

***Customer***

*Facility Name:* *Mews 1 Fox Chapel*

*Address:* *300 Fox Chapel Rd*
*Pittsburgh, PA 15238*

*Matrix:* *Recreational Water*

*Source Type:* *Pool*

***Sample Collection***

*Date:* *10/22/26*
*Time:* 9:05 AM
*Method:* *Grab*

***Sample Final Analysis***

*Date:* *10/24/26*
*Time:* *5:30 PM*
*Analyst:* *AS*

| Accredited Analysis | Results | Reporting limit | Incubation Date/Time | | Analyst | Method |
|---|---|---|---|---|---|---|
| Escherichia Coli: | Absent | Absent | 10/22/26 | 5:00 PM | SL | SM 9222G |
| Total coliforms: | 0/100mls | 2/100mls | 10/22/26 | 5:00 PM | SL | SM 9222B |
| Standard plate count: | 0/ml | 200/ml | 10/22/26 | 5:00 PM | SL | SM 9215B |

| Field Analysis | Results | Reporting limit | Date/Time | | Analyst | Method |
|---|---|---|---|---|---|---|
| pH: | 7.4 SU | 7.2 - 7.8 SU | 10/22/26 | 9:05 AM | MH | DPD |
| Chlorine: | 3.0 mg/l | 1.0 - 5.0 mg/l | 10/22/26 | 9:05 AM | MH | DPD |
| Turbidity: | 1 NTU | 1 - 2 NTU | 10/22/26 | 9:05 AM | MH | Visual |

**Sample comments**

( When exceeding reporting limit pool or spa is unfit)

Andre Smith

Andre Smith, Lead Supervisor