Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

C-2

Lab# 286

Customer

Facility Name: *Spring Hill Suites*

Address: *223 Federal St.*
Pittsburgh, PA 15212

Matrix: *Recreational Water*

Source Type: *Pool*

Sample Collection

Date: *10/19/26*
Time: 3:13 PM
Method: *Grab*

Sample Final Analysis

Date: *10/22/26*
Time: *9:30 AM*
Analyst: *JC*

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	10/20/26	9:25 AM	JC	SM 9222G
Total coliforms:	0/100mls	2/100mls	10/20/26	9:25 AM	JC	SM 9222B
Standard plate count:	0/ml	200/ml	10/19/26	5:30 PM	SL	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.5 SU	7.2 - 7.8 SU	10/19/26	3:13 PM	SL	DPD
Chlorine:	2.0 mg/l	1.0 - 5.0 mg/l	10/19/26	3:13 PM	SL	DPD
Turbidity:	1 NTU	1 - 2 NTU	10/19/26	3:13 PM	SL	Visual

Sample comments

Andre Smith

Andre Smith, Lead Supervisor

(When exceeding reporting limit pool or spa is unfit)