Lab ID No. 02-04041

Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665

APM

Lab# *2608*

Laboratory Analysis Report

Customer

Facility Name: *Yards @ 3 Crossings*

Address: *2645 Railroad St.*
Pittsburgh,PA 15222

Matrix: *Recreational Water*

Source Type: *Spa*

Sample Collection

Date: *10/19/26*
Time: 9:11 AM
Method: *Grab*

Sample Final Analysis

Date: *10/22/26*
Time: *9:30 AM*
Analyst: *JC*

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	10/20/26	9:25 AM	JC	SM 9222G
Total coliforms:	0/100mls	2/100mls	10/20/26	9:25 AM	JC	SM 9222B
Standard plate count:	0/ml	200/ml	10/19/26	5:30 PM	SL	SM 9215B

Additional Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Fecal Streptococcus	0/100mls	2/100mls	10/20/26	10:00 AM	JC	SM 9230C

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.4 SU	7.2 - 7.8 SU	10/19/26	9:11 AM	SL	DPD
Chlorine:	2.0 mg/l	1.0 - 5.0 mg/l	10/19/26	9:11 AM	SL	DPD
Turbidity:	1 NTU	1 - 2 NTU	10/19/26	9:11 AM	SL	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith

Andre Smith, Lead Supervisor