Dreams Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

PPS

Lab# 027

Customer

Facility Name: *Brashear High School*

Address: *590 Crane Ave*
Pittsburgh, PA 15216

Matrix: *Recreational Water*

Source Type: *Pool Shallow*

Sample Collection

Date: *10/19/26*
Time: 9:43 AM
Method: *Grab*

Sample Final Analysis

Date: *10/22/26*
Time: *9:00 AM*
Analyst: *JC*

Accredited Analysis	Results	Rating	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	A	10/20/26	8:55 AM	JC	SM 9222G
Total coliforms:	0/100mls	A	10/20/26	8:55 AM	JC	SM 9222B
Standard plate count:	0/ml	A	10/19/26	2:45 PM	AS	SM 9215B

Field Analysis	Results	Rating	Date/Time		Analyst	Method
pH:	7.4 SU	A	10/19/26	9:43 AM	JT	DPD
Chlorine:	3.0 mg/l	A	10/19/26	9:43 AM	JT	DPD
Turbidity:	1 NTU	A	10/19/26	9:43 AM	JT	Visual

Sample comments

Andre Smith

Andre Smith, Lead Supervisor

(When exceeding reporting limit pool or spa is unfit)