



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041
W-12

Lab# 2014

Customer

Facility Name: Allegheny C.C.
Address: 250 Country Club Rd
Sewickley, PA 15143

Sample Collection

Date: 8/27/26
Time: 12:03 PM
Method: Grab

Sample Final Analysis

Date: 8/30/26
Time: 5:00 PM
Analyst: AS

Matrix: Recreational Water
Source Type: Pool

Accredited Analysis	Results	Reporting limit	Incubation Date/Time	Analyst	Method
Escherichia Coli:	Absent	Absent	8/27/26 4:40 PM	SL	SM 9222G
Total coliforms:	0/100mls	2/100mls	8/27/26 4:40 PM	SL	SM 9222B
Standard plate count:	0/ml	200/ml	8/27/26 4:30 PM	SL	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time	Analyst	Method
pH:	7.3 SU	7.2 - 7.8 SU	8/27/26 12:03 PM	SL	DPD
Chlorine:	1.0 mg/l	1.0 - 5.0 mg/l	8/27/26 12:03 PM	SL	DPD
Turbidity:	1 NTU	1 - 2 NTU	8/27/26 12:03 PM	SL	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor