



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

Service

Lab# 2750

Customer

Facility Name: Lakemont Farms

Address: Lakeview Dr.
Bridgeville, PA 15017

Matrix: Recreational Water

Source Type: Baby Pool

Sample Collection

Date: 8/24/26

Time: 1:50 PM

Method: Grab

Sample Final Analysis

Date: 8/27/26

Time: 11:00 AM

Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	8/25/26	10:45 AM	AS	SM 9222G
Total coliforms:	0/100mls	2/100mls	8/25/26	10:45 AM	AS	SM 9222B
Standard plate count:	0/ml	200/ml	8/24/26	5:55 PM	AS	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.4 SU	7.2 - 7.8 SU	8/24/26	1:50 PM	AS	DPD
Chlorine:	1.0 mg/l	1.0 - 5.0 mg/l	8/24/26	1:50 PM	AS	DPD
Turbidity:	1 NTU	1 - 2 NTU	8/24/26	1:50 PM	AS	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor