



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

S-11

Lab# 024

Customer

Facility Name: Bethel Park HS
Address: 309 Church Rd.
Bethel Park, PA 15102

Sample Collection

Date: 8/26/26
Time: 1:47 PM
Method: Grab

Matrix: Recreational Water
Source Type: Shallow End

Sample Final Analysis

Date: 8/29/26
Time: 11:30 AM
Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	8/27/26	11:20 AM	AH	SM 9222G
Total coliforms:	0/100mls	2/100mls	8/27/26	11:20 AM	AH	SM 9222B
Standard plate count:	0/ml	200/ml	8/26/26	5:00 PM	AH	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.4 SU	7.2 - 7.8 SU	8/26/26	1:47 PM	SL	DPD
Chlorine:	1.0 mg/l	1.0 - 5.0 mg/l	8/26/26	1:47 PM	SL	DPD
Turbidity:	1 NTU	1 - 2 NTU	8/26/26	1:47 PM	SL	Visual

Sample comments

Andre Smith, Lead Supervisor

(When exceeding reporting limit pool or spa is unfit)