



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

W-10

Lab# 2061

Customer

Facility Name: *Brodhead North Associates*

Address: *3339 Brodhead Rd.*
Alliquippa, PA 15001

Matrix: *Recreational Water*

Source Type: *Pool*

Sample Collection

Date: *8/24/26*

Time: *12:07 PM*

Method: *Grab*

Sample Final Analysis

Date: *8/27/26*

Time: *12:00 PM*

Analyst: *AS*

Accredited Analysis	Results	Reporting limit	Incubation	Date/Time	Analyst	Method
Escherichia Coli:	Absent	Absent	8/25/26	11:40 AM	AS	SM 9222G
Total coliforms:	0/100mls	2/100mls	8/25/26	11:40 AM	AS	SM 9222B
Standard plate count:	0/ml	200/ml	8/24/26	6:45 PM	AS	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time	Analyst	Method	
pH:	7.4 SU	7.2 - 7.8 SU	8/24/26	12:07 PM	AMH	DPD
Chlorine:	7.5 mg/l	1.0 - 5.0 mg/l	8/24/26	12:07 PM	AMH	DPD
Turbidity:	1 NTU	1 - 2 NTU	8/24/26	12:07 PM	AMH	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor