



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

W-12

Lab# 2098

Customer

Facility Name: Chartiers Valley C.C.

Address: 601 Baldwin Road
Pittsburgh, PA 15205

Matrix: Recreational Water

Source Type: Shallow End

Sample Collection

Date: 8/24/26

Time: 11:37 AM

Method: Grab

Sample Final Analysis

Date: 8/27/26

Time: 11:00 AM

Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time	Analyst	Method
Escherichia Coli:	Absent	Absent	8/25/26 10:45 AM	AS	SM 9222G
Total coliforms:	0/100mls	2/100mls	8/25/26 10:45 AM	AS	SM 9222B
Standard plate count:	10/ml	200/ml	8/24/26 5:55 PM	AS	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time	Analyst	Method
pH:	7.6 SU	7.2 - 7.8 SU	8/24/26 11:37 AM	MH	DPD
Chlorine:	0.0 mg/l	1.0 - 5.0 mg/l	8/24/26 11:37 AM	MH	DPD
Turbidity:	1 NTU	1 - 2 NTU	8/24/26 11:37 AM	MH	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor