



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

C-11

Lab# 377

Customer

Facility Name: *Drury Hotel*
Address: *745 Grant St.*
Pittsburgh, PA 15219

Matrix: *Recreational Water*

Source Type: *Spa*

Sample Collection

Date: *8/24/26*
Time: *11:45 AM*
Method: *Grab*

Sample Final Analysis

Date: *8/27/26*
Time: *11:00 AM*
Analyst: *AS*

Accredited Analysis	Results	Reporting limit	Incubation Date/Time	Analyst	Method
----------------------------	----------------	------------------------	-----------------------------	----------------	---------------

Escherichia Coli:	Absent	Absent	8/25/26	10:45 AM	AS	SM 9222G
Total coliforms:	0/100mls	2/100mls	8/25/26	10:45 AM	AS	SM 9222B
Standard plate count:	0/ml	200/ml	8/24/26	5:55 PM	AS	SM 9215B

Additional Analysis	Results	Reporting limit	Incubation Date/Time	Analyst	Method
----------------------------	----------------	------------------------	-----------------------------	----------------	---------------

Fecal Streptococcus	0/100mls	2/100mls	8/25/26	11:40 AM	AS	SM 9230C
---------------------	----------	----------	---------	----------	----	----------

Field Analysis	Results	Reporting limit	Date/Time	Analyst	Method
-----------------------	----------------	------------------------	------------------	----------------	---------------

pH:	7.4 SU	7.2 - 7.8 SU	8/24/26	11:45 AM	MB	DPD
Chlorine:	2.0 mg/l	1.0 - 5.0 mg/l	8/24/26	11:45 AM	MB	DPD
Turbidity:	1 NTU	1 - 2 NTU	8/24/26	11:45 AM	MB	Visual

Sample comments

Andre Smith

Andre Smith, Lead Supervisor

(When exceeding reporting limit pool or spa is unfit)