



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

S-16

Lab# 160

Customer

Facility Name: *Holiday Inn Express*

Address: *810 Highland Meadow Dr.*
Washington, PA 15301

Sample Collection

Date: *8/24/26*
Time: *12:15 PM*
Method: *Grab*

Matrix: *Recreational Water*

Sample Final Analysis

Date: *8/27/26*
Time: *10:00 AM*
Analyst: *AS*

Source Type: *Spa*

Accredited Analysis	Results	Reporting limit	Incubation Date/Time	Analyst	Method
---------------------	---------	-----------------	----------------------	---------	--------

Escherichia Coli:	Absent	Absent	8/25/26	9:30 AM	AS	SM 9222G
-------------------	--------	--------	---------	---------	----	----------

Total coliforms:	0/100mls	2/100mls	8/25/26	9:30 AM	AS	SM 9222B
------------------	----------	----------	---------	---------	----	----------

Standard plate count:	0/ml	200/ml	8/24/26	4:00 PM	AS	SM 9215B
-----------------------	------	--------	---------	---------	----	----------

Additional Analysis	Results	Reporting limit	Incubation Date/Time	Analyst	Method
---------------------	---------	-----------------	----------------------	---------	--------

Fecal Streptococcus	0/100mls	2/100mls	8/25/26	11:40 AM	AS	SM 9230C
---------------------	----------	----------	---------	----------	----	----------

Field Analysis	Results	Reporting limit	Date/Time	Analyst	Method
----------------	---------	-----------------	-----------	---------	--------

pH:	7.8 SU	7.2 - 7.8 SU	8/24/26	12:15 PM	JM	DPD
-----	--------	--------------	---------	----------	----	-----

Chlorine:	5.0 mg/l	1.0 - 5.0 mg/l	8/24/26	12:15 PM	JM	DPD
-----------	----------	----------------	---------	----------	----	-----

Turbidity:	1 NTU	1 - 2 NTU	8/24/26	12:15 PM	JM	Visual
------------	-------	-----------	---------	----------	----	--------

Sample comments

Andre Smith

Andre Smith, Lead Supervisor

(When exceeding reporting limit pool or spa is unfit)